

GOVERNMENT OF ARUNACHAL PRADESH
PUBLIC WORKS DEPARTMENT

Gram : NIRMANPALDO
Ph : 0360-2244 379
Fax No.0360-2248344
E-mail- cenlg @ yahoo.co.in

OFFICE OF THE
EXECUTIVE ENGINEER
NAHARLAGUN DIVISION PWD AP
NAHARLAGUN-791 110

NO OBJECTION CERTIFICATE


1	Name of the Officer	: Chukhu Tacho (AEPWD)
2	Name of the School	: KV-1, Itanagar
3	Location with name of Education District/Locality	: C-Sector, Naharlagun, Papum Pare Distt. (A.P)
4	Classification of the building	: RCC Frame structure, (G+1)
5	Period/ Session of which the certificate is issued	: 2021-2022
6	Nature of defects, if any	
	a) Foundation and basement:	: None
	b) Superstructure	: None
	c) Door and windows	: Rusted and need minor repair.
	d) Wood works	: None
	e) Roof	: There are leakage of water at various locations.
	f) Flooring	: None
	g) Miscellaneous (Crack etc):	: A few minor and major cracks are seen at different components of building.
7	Any major defects noticed which will render the building unsafe in any manner:	: None
8	Whether maintenance works have been done properly	: Yes, the building has been maintained but need major maintenance works for leaking roof and cracks.
9	Whether the structure is sound or not fit for running school/institute.	: Yes, building is fit for running school for 1(one) year.

Certified that the school building was inspected by me on 25th May' 2021 and found the building to be structurally fit for running of a School/ Institute for the period for the reason stated above.

Place: Naharlagun
Date: 25th May' 2021.

(Er Chukhu Tacho)
Assistant Engineer
PWD, Naharlagun, A.P.

Counter Signed


Principal/ प्राचार्य
Kendriya Vidyalaya, No.1 Itanagar
केन्द्रीय विद्यालय, नं.१ इटानगर

(Er. Tech. Naho)
Executive Engineer
Naharlagun Division
PWD:: A.P.: Naharlagun